

Callisburg Water & Sewer Specifications for Water Lines

Anyone applying for water service where an extension to the City's main line would be required, must follow the specifications below.

SPECIFICATIONS

		Initials
01.	The party seeking approval to connect must meet with the Callisburg City Council and get approval.	
02.	No construction will begin until all right of way easements, permits and certificates of liability insurance are in the possession of the city secretary.	
03.	The cost of laying the lines, road bores, & materials needed to make the connection to the main line will be at the applicant's expense.	
04.	All lines will be required to meet county, state, & federal regulations and must be inspected by a City employee before they are covered.	
05.	All water lines shall be PVC class 200 or better, slip joint pipe & must meet AWWA requirements. The minimum water line size shall be six-inches (6").	
06.	All lines will have 36 inches of cover over the pipe and be covered to the full satisfaction of the City.	
07.	All water lines under roads and driveways will be in casing.	
08.	All L's, T's, and ends will be blocked with concrete slabs or large flat rocks and inspected by a City employee before being covered.	
09.	All lines crossing creeks will be in casing and the casing will extend a minimum of 6 feet on each side of the creek. PVC casings will be allowed.	
10.	The water line must be bedded in sand if determined necessary by the City.	
11.	The water line being laid will reach to the far corner of the applicant's property so to avoid having to cut across their driveway should another party need to connect to the main line.	
12.	A 6" valve and a flush-out valve will be required at the end of the line extension.	
13.	The applicant who lays the line will be responsible for all maintenance of the line for one year. After one year the City of Callisburg Water & Sewer will take over the maintenance of the line provided it meets all specifications.	

14.	<p>Once water or sewer main extensions have been accepted by the City, any party seeking service connection to these mains are subject to a pro rata charge associated with such connection. The original installer shall have 30 calendar days from the acceptance of the utility to establish the pro rata cost for the utility line installed by providing the City with copies of invoices paid for the construction of said utility line. Failure to provide the pro rata cost within the time stipulated will result in the loss of pro rata for that portion of the utility line on which connections are made. The party, firm, or corporation seeking a service connection to said main shall pay the pro rata to the original installer of the main, not the City. It is the original installer's responsibility to keep on file with the City a current address and telephone number so that they may be contacted when a service connection is proposed to the main. Failure to have a current address and phone number on file will result in loss of pro rata. The original installer shall be allowed to recover pro rata within the first five (5) years of the acceptance of the line by the City.</p>	
15.	<p>No exceptions to these specifications will be granted, except for those put in writing and approved by the Callisburg City Council.</p>	

I have read and received a copy of the water line specifications. I agree to follow these specifications and understand failure to do so will result in the refusal to allow a connection to the City's main line. Callisburg Water & Sewer will immediately terminate water service if a violation is discovered after the connection has been made.

Signature of Applicant

Date

City Representative

Date